

Compliance Maintenance Annual Report

Dale Sanitary District No 1 Wwtf

Last Updated: Reporting For:
5/17/2018 2017

Influent Flow and Loading

1. Monthly Average Flows and (C)BOD Loadings

1.1 Verify the following monthly flows and (C)BOD loadings to your facility.

Outfall No. 701	Influent Monthly Average Flow, MGD	x	Influent Monthly Average (C)BOD Concentration mg/L	x	8.34	=	Influent Monthly Average (C)BOD Loading, lbs/day
January	0.0304	x	169	x	8.34	=	43
February	0.0275	x	222	x	8.34	=	51
March	0.0342	x	456	x	8.34	=	130
April	0.0405	x	136	x	8.34	=	46
May	0.0335	x	158	x	8.34	=	44
June	0.0261	x	259	x	8.34	=	56
July	0.0230	x	229	x	8.34	=	44
August	0.0199	x	258	x	8.34	=	43
September	0.0206	x	284	x	8.34	=	49
October	0.0234	x	342	x	8.34	=	67
November	0.0204	x	289	x	8.34	=	49
December	0.0205	x	428	x	8.34	=	73

2. Maximum Monthly Design Flow and Design (C)BOD Loading

2.1 Verify the design flow and loading for your facility.

Design	Design Factor	x	%	=	% of Design
Max Month Design Flow, MGD	.06	x	90	=	0.054
		x	100	=	.06
Design (C)BOD, lbs/day	125	x	90	=	112.5
		x	100	=	125

2.2 Verify the number of times the flow and (C)BOD exceeded 90% or 100% of design, points earned, and score:

	Months of Influent	Number of times flow was greater than 90% of	Number of times flow was greater than 100% of	Number of times (C)BOD was greater than 90% of design	Number of times (C)BOD was greater than 100% of design
January	1	0	0	0	0
February	1	0	0	0	0
March	1	0	0	1	1
April	1	0	0	0	0
May	1	0	0	0	0
June	1	0	0	0	0
July	1	0	0	0	0
August	1	0	0	0	0
September	1	0	0	0	0
October	1	0	0	0	0
November	1	0	0	0	0
December	1	0	0	0	0
Points per each		2	1	3	2
Exceedances		0	0	1	1
Points		0	0	3	2
Total Number of Points					5

Compliance Maintenance Annual Report

Dale Sanitary District No 1 Wwtf

Last Updated: Reporting For:
5/17/2018 2017

3. Flow Meter

3.1 Was the influent flow meter calibrated in the last year?
 Yes Enter last calibration date (MM/DD/YYYY)

No

If No, please explain:

4. Sewer Use Ordinance

4.1 Did your community have a sewer use ordinance that limited or prohibited the discharge of excessive conventional pollutants ((C)BOD, SS, or pH) or toxic substances to the sewer from industries, commercial users, hauled waste, or residences?

Yes

No

If No, please explain:

4.2 Was it necessary to enforce the ordinance?

Yes

No

If Yes, please explain:

5. Septage Receiving

5.1 Did you have requests to receive septage at your facility?

Septic Tanks

Holding Tanks

Grease Traps

Yes

Yes

Yes

No

No

No

5.2 Did you receive septage at your facility? If yes, indicate volume in gallons.

Septic Tanks

Yes

gallons

No

Holding Tanks

Yes

gallons

No

Grease Traps

Yes

gallons

No

5.2.1 If yes to any of the above, please explain if plant performance is affected when receiving any of these wastes.

6. Pretreatment

6.1 Did your facility experience operational problems, permit violations, biosolids quality concerns, or hazardous situations in the sewer system or treatment plant that were attributable to commercial or industrial discharges in the last year?

Yes

No

If yes, describe the situation and your community's response.

6.2 Did your facility accept hauled industrial wastes, landfill leachate, etc.?

Compliance Maintenance Annual Report

Dale Sanitary District No 1 Wwtf

Last Updated: Reporting For:

5/17/2018

2017

Yes

No

If yes, describe the types of wastes received and any procedures or other restrictions that were in place to protect the facility from the discharge of hauled industrial wastes.

--

Total Points Generated	5
Score (100 - Total Points Generated)	95
Section Grade	A

Compliance Maintenance Annual Report

Dale Sanitary District No 1 Wwtf

Last Updated: Reporting For:
5/17/2018 2017

Effluent Quality and Plant Performance (BOD/CBOD)

1. Effluent (C)BOD Results

1.1 Verify the following monthly average effluent values, exceedances, and points for BOD or CBOD

Outfall No. 001	Monthly Average Limit (mg/L)	90% of Permit Limit > 10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	16	14.4	6	1	0	0
February	16	14.4	9	1	0	0
March	16	14.4	8	1	0	0
April	16	14.4	14	1	0	0
May	16	14.4	9	1	0	0
June	16	14.4	4	1	0	0
July	16	14.4	8	1	0	0
August	16	14.4	1	1	0	0
September	16	14.4	0	1	0	0
October	16	14.4	0	1	0	0
November	16	14.4	1	1	0	0
December	16	14.4	7	1	0	0

* Equals limit if limit is <= 10

Months of discharge/yr	12		
Points per each exceedance with 12 months of discharge		7	3
Exceedances		0	0
Points		0	0
Total number of points			0

NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge. Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

2. Flow Meter Calibration

2.1 Was the effluent flow meter calibrated in the last year?

Yes Enter last calibration date (MM/DD/YYYY)

2017-06-13

No

If No, please explain:

3. Treatment Problems

3.1 What problems, if any, were experienced over the last year that threatened treatment?

none

4. Other Monitoring and Limits

4.1 At any time in the past year was there an exceedance of a permit limit for any other pollutants such as chlorides, pH, residual chlorine, fecal coliform, or metals?

Yes

No

Compliance Maintenance Annual Report

Dale Sanitary District No 1 Wwtf

Last Updated: Reporting For:
5/17/2018 2017

If Yes, please explain:

4.2 At any time in the past year was there a failure of an effluent acute or chronic whole effluent toxicity (WET) test?
 Yes
 No

If Yes, please explain:

4.3 If the biomonitoring (WET) test did not pass, were steps taken to identify and/or reduce source(s) of toxicity?
 Yes
 No
 N/A

Please explain unless not applicable:

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Dale Sanitary District No 1 Wwtf

Last Updated: Reporting For:
5/17/2018 2017

Effluent Quality and Plant Performance (Total Suspended Solids)

1. Effluent Total Suspended Solids Results

1.1 Verify the following monthly average effluent values, exceedances, and points for TSS:

Outfall No. 001	Monthly Average Limit (mg/L)	90% of Permit Limit >10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	60	54	11	1	0	0
February	60	54	9	1	0	0
March	60	54	8	1	0	0
April	60	54	23	1	0	0
May	60	54	23	1	0	0
June	60	54	10	1	0	0
July	60	54	8	1	0	0
August	60	54	6	1	0	0
September	60	54	1	1	0	0
October	60	54	0	1	0	0
November	60	54	2	1	0	0
December	60	54	8	1	0	0
* Equals limit if limit is <= 10						
Months of Discharge/yr				12		
Points per each exceedance with 12 months of discharge:					7	3
Exceedances					0	0
Points					0	0
Total Number of Points						0

0

NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge.

Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

no violations

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Dale Sanitary District No 1 Wwtf

Last Updated: Reporting For:
5/17/2018 2017

Ponds And Lagoon Leakage

1. Pond Lining

1.1 What material was used to line your ponds?

plastic lined with clay

2. Flow Measurements

2.1 Did you measure influent flow to your wastewater ponds or lagoons?

- Yes (0 points)
- No (40 points) (Go to question 6)

2.1.1 Method of influent flow measurement:

Greyline Doppler flow meter

2.2 Did you measure effluent flow discharged from your wastewater system either to the land disposal system or to the receiving stream?

- Yes (0 points)
- No (40 points) (Go to question 6)
- No Discharge (0 points)

2.2.1 Method of effluent flow measurement:

89 degree v-notch weir , ultrasonic badger flow meter

0

3. Total Flow Volumes

3.1 Total monthly influent and effluent flow volumes from the pond/lagoon system during the last calendar year.

Total Monthly Influent Volume		Total Monthly Effluent Volume
.9425	JANUARY	1.113
.7704	FEBRUARY	.863
1.0587	MARCH	1.128
.9304	APRIL	.928
1.0388	MAY	.928
.782	JUNE	.828
.7126	JULY	.56
.6165	AUGUST	.547
.6173	SEPTEMBER	.485
.7255	OCTOBER	.725
.612	NOVEMBER	.605
.6357	DECEMBER	.682
9.4424	YEARLY TOTAL	9.3920

3.2 From the Yearly Total influent and effluent volumes above, total effluent is divided by total influent and converted to a percent of volume loss.

Total effluent, MG => 9.3920
 ----- = 0.995 <= effl / infl ratio
 Total influent, MG => 9.4424

Conversion to a percent of volume loss:

(1-effl/infl ratio) * 100 = 0.5 % of influent lost and not discharged with effluent

Compliance Maintenance Annual Report

Dale Sanitary District No 1 Wwtf

Last Updated: Reporting For:
5/17/2018 2017

4. Surface Area

4.1 What was the total wastewater surface area of the ponds/lagoons at operating level (do not include seepage cells)?

Acres

5. Leakage Rate Estimation

5.1 Total influent volume (in MG) minus total effluent volume (in MG) plus or minus the change in pond/lagoon storage (in MG) is the net wastewater loss. The net loss divided by 0.000365 equals the estimated leakage amount in gpd.

Total Annual Influent (MG)	9.4424	
Total Annual Effluent (MG)	9.3920	
Estimated Net Loss (MG)	0.0504	
Estimated Leakage Amount (gpd)		138

If you have a *Department approved* method for determining a change in storage volume, enter the storage change last year in MG below.

o Storage Increase: Enter amount in MG ->

o Storage Decrease: Enter amount in MG ->

5.2 CMAR Estimated Leakage Rate in gallons per acre per day (gpad): The CMAR Estimated Leakage Rate in gpad is the leakage amount in gpd (from part 5.1) divided by the total pond surface area (from question 4).

Leakage Amount (gpd)		Acres		CMAR Estimated Leakage Rate
138	divided by	1.2	=	115

6. On Site Leakage Testing

6.1 Did you conduct an on-site, field water balance/leakage test on your ponds or lagoons that was approved by the Department and is still valid?

o Yes Year

● No

If yes, what was the field Test Calculated Leakage Rate for your ponds/lagoons?

gpad

NOTE: if 6.1 is answered Yes, the value entered above in gpad will be used in 7.1 to compute points generated.

6.2 Leakage Rate Comments:

7. Estimated Leakage Rate and Points

7.1 The CMAR Estimated Leakage Rate (from 5) is used to determine the points generated in the table below.

If an approved field test was conducted and the results are still valid and accepted by the Department, the Field Calculated Leakage rate (from 5.2) is used to determine the points earned from the table below

gpad	points
0 - 1,000	0
1,001 - 2,000	10
2,001 - 4,000	20
4,001 - 7,000	30
> 7,000	40

Compliance Maintenance Annual Report

Dale Sanitary District No 1 Wwtf

Last Updated: Reporting For:

5/17/2018

2017

Based on the leakage rate in gpad, the points earned are:

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Dale Sanitary District No 1 Wwtf

Last Updated: Reporting For:
5/17/2018 2017

Biosolids Quality and Management

<p>1. Biosolids Use/Disposal</p> <p>1.1 How did you use or dispose of your biosolids? (Check all that apply)</p> <p><input type="checkbox"/> Land applied under your permit</p> <p><input type="checkbox"/> Publicly Distributed Exceptional Quality Biosolids</p> <p><input type="checkbox"/> Hauled to another permitted facility</p> <p><input type="checkbox"/> Landfilled</p> <p><input type="checkbox"/> Incinerated</p> <p><input checked="" type="checkbox"/> Other</p> <p>NOTE: If you did not remove biosolids from your system, please describe your system type such as lagoons, reed beds, recirculating sand filters, etc.</p> <p>1.1.1 If you checked Other, please describe:</p> <div style="border: 1px solid black; padding: 2px; margin-top: 5px;">wastewater treatment facility is a lagoon system.</div>	
<p>6. Biosolids Storage</p> <p>6.1 How many days of actual, current biosolids storage capacity did your wastewater treatment facility have either on-site or off-site?</p> <p><input checked="" type="radio"/> >= 180 days (0 Points)</p> <p><input type="radio"/> 150 - 179 days (10 Points)</p> <p><input type="radio"/> 120 - 149 days (20 Points)</p> <p><input type="radio"/> 90 - 119 days (30 Points)</p> <p><input type="radio"/> < 90 days (40 Points)</p> <p><input type="radio"/> N/A (0 Points)</p> <p>6.2 If you checked N/A above, explain why.</p> <div style="border: 1px solid black; height: 20px; margin-top: 5px;"></div>	0
<p>7. Issues</p> <p>7.1 Describe any outstanding biosolids issues with treatment, use or overall management:</p> <div style="border: 1px solid black; padding: 2px; margin-top: 5px;">none</div>	

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Dale Sanitary District No 1 Wwtf

Last Updated: Reporting For:
5/17/2018 2017

Staffing and Preventative Maintenance (All Treatment Plants)

<p>1. Plant Staffing</p> <p>1.1 Was your wastewater treatment plant adequately staffed last year?</p> <ul style="list-style-type: none"><input checked="" type="radio"/> Yes<input type="radio"/> No <p>If No, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>Could use more help/staff for:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>1.2 Did your wastewater staff have adequate time to properly operate and maintain the plant and fulfill all wastewater management tasks including recordkeeping?</p> <ul style="list-style-type: none"><input checked="" type="radio"/> Yes<input type="radio"/> No <p>If No, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>	
<p>2. Preventative Maintenance</p> <p>2.1 Did your plant have a documented AND implemented plan for preventative maintenance on major equipment items?</p> <ul style="list-style-type: none"><input checked="" type="radio"/> Yes (Continue with question 2)<input type="radio"/> No (40 points) <p>If No, please explain, then go to question 3:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>2.2 Did this preventative maintenance program depict frequency of intervals, types of lubrication, and other tasks necessary for each piece of equipment?</p> <ul style="list-style-type: none"><input checked="" type="radio"/> Yes<input type="radio"/> No (10 points) <p>2.3 Were these preventative maintenance tasks, as well as major equipment repairs, recorded and filed so future maintenance problems can be assessed properly?</p> <ul style="list-style-type: none"><input checked="" type="radio"/> Yes<ul style="list-style-type: none"><input checked="" type="radio"/> Paper file system<input type="radio"/> Computer system<input type="radio"/> Both paper and computer system<input type="radio"/> No (10 points)	0
<p>3. O&M Manual</p> <p>3.1 Does your plant have a detailed O&M and Manufacturer Equipment Manuals that can be used as a reference when needed?</p> <ul style="list-style-type: none"><input checked="" type="radio"/> Yes<input type="radio"/> No	
<p>4. Overall Maintenance /Repairs</p> <p>4.1 Rate the overall maintenance of your wastewater plant.</p> <ul style="list-style-type: none"><input type="radio"/> Excellent<input checked="" type="radio"/> Very good<input type="radio"/> Good<input type="radio"/> Fair<input type="radio"/> Poor <p>Describe your rating:</p> <div style="border: 1px solid black; padding: 2px;">daily visits by the operator</div>	

Compliance Maintenance Annual Report

Dale Sanitary District No 1 Wwtf

Last Updated: Reporting For:
5/17/2018 2017

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Dale Sanitary District No 1 Wwtf

Last Updated: Reporting For:
5/17/2018 2017

Operator Certification and Education

<p>1. Operator-In-Charge</p> <p>1.1 Did you have a designated operator-in-charge during the report year?</p> <p>● Yes (0 points)</p> <p>○ No (20 points)</p> <p>Name: <input style="width: 300px;" type="text" value="CORNELIUS H VANVOORHIS"/></p> <p>Certification No: <input style="width: 150px;" type="text" value="33363"/></p>	0																																																																																								
<p>2. Certification Requirements</p> <p>2.1 In accordance with Chapter NR 114.56 and 114.57, Wisconsin Administrative Code, what level and subclass(es) were required for the operator-in-charge (OIC) to operate the wastewater treatment plant and what level and subclass(es) were held by the operator-in-charge?</p> <table border="1" style="width: 100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th rowspan="2">Sub Class</th> <th rowspan="2">SubClass Description</th> <th colspan="2">WWTP</th> <th colspan="2">OIC</th> </tr> <tr> <th>Basic</th> <th>OIT</th> <th>Basic</th> <th>Advanced</th> </tr> </thead> <tbody> <tr><td>A1</td><td>Suspended Growth Processes</td><td></td><td></td><td>X</td><td></td></tr> <tr><td>A2</td><td>Attached Growth Processes</td><td></td><td></td><td></td><td></td></tr> <tr><td>A3</td><td>Recirculating Media Filters</td><td></td><td></td><td></td><td></td></tr> <tr><td>A4</td><td>Ponds, Lagoons and Natural</td><td>X</td><td>X</td><td></td><td></td></tr> <tr><td>A5</td><td>Anaerobic Treatment Of Liquid</td><td></td><td></td><td></td><td></td></tr> <tr><td>B</td><td>Solids Separation</td><td></td><td></td><td>X</td><td></td></tr> <tr><td>C</td><td>Biological Solids/Sludges</td><td></td><td></td><td>X</td><td></td></tr> <tr><td>P</td><td>Total Phosphorus</td><td></td><td></td><td></td><td></td></tr> <tr><td>N</td><td>Total Nitrogen</td><td></td><td></td><td></td><td></td></tr> <tr><td>D</td><td>Disinfection</td><td></td><td></td><td>X</td><td></td></tr> <tr><td>L</td><td>Laboratory</td><td></td><td></td><td>X</td><td></td></tr> <tr><td>U</td><td>Unique Treatment Systems</td><td></td><td></td><td></td><td></td></tr> <tr><td>SS</td><td>Sanitary Sewage Collection</td><td>X</td><td>NA</td><td>NA</td><td>NA</td></tr> </tbody> </table> <p>2.2 Was the operator-in-charge certified at the appropriate level and subclass(es) to operate this plant? (Note: Certification in subclass SS, N and A5 not required in 2016; subclass SS is basic level only.)</p> <p>● Yes (0 points)</p> <p>○ No (20 points)</p>	Sub Class	SubClass Description	WWTP		OIC		Basic	OIT	Basic	Advanced	A1	Suspended Growth Processes			X		A2	Attached Growth Processes					A3	Recirculating Media Filters					A4	Ponds, Lagoons and Natural	X	X			A5	Anaerobic Treatment Of Liquid					B	Solids Separation			X		C	Biological Solids/Sludges			X		P	Total Phosphorus					N	Total Nitrogen					D	Disinfection			X		L	Laboratory			X		U	Unique Treatment Systems					SS	Sanitary Sewage Collection	X	NA	NA	NA	0
Sub Class			SubClass Description	WWTP		OIC																																																																																			
	Basic	OIT		Basic	Advanced																																																																																				
A1	Suspended Growth Processes			X																																																																																					
A2	Attached Growth Processes																																																																																								
A3	Recirculating Media Filters																																																																																								
A4	Ponds, Lagoons and Natural	X	X																																																																																						
A5	Anaerobic Treatment Of Liquid																																																																																								
B	Solids Separation			X																																																																																					
C	Biological Solids/Sludges			X																																																																																					
P	Total Phosphorus																																																																																								
N	Total Nitrogen																																																																																								
D	Disinfection			X																																																																																					
L	Laboratory			X																																																																																					
U	Unique Treatment Systems																																																																																								
SS	Sanitary Sewage Collection	X	NA	NA	NA																																																																																				
<p>3. Succession Planning</p> <p>3.1 In the event of the loss of your designated operator-in-charge, did you have a contingency plan to ensure the continued proper operation and maintenance of the plant that includes one or more of the following options (check all that apply)?</p> <p><input type="checkbox"/> One or more additional certified operators on staff</p> <p><input type="checkbox"/> An arrangement with another certified operator</p> <p><input checked="" type="checkbox"/> An arrangement with another community with a certified operator</p> <p><input type="checkbox"/> An operator on staff who has an operator-in-training certificate for your plant and is expected to be certified within one year</p> <p><input type="checkbox"/> A consultant to serve as your certified operator</p> <p><input type="checkbox"/> None of the above (20 points)</p> <p>If "None of the above" is selected, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>	0																																																																																								
<p>4. Continuing Education Credits</p>																																																																																									

Compliance Maintenance Annual Report

Dale Sanitary District No 1 Wwtf

Last Updated: Reporting For:

5/17/2018

2017

4.1 If you had a designated operator-in-charge, was the operator-in-charge earning Continuing Education Credits at the following rates?

OIT and Basic Certification:

- Averaging 6 or more CECs per year.
- Averaging less than 6 CECs per year.

Advanced Certification:

- Averaging 8 or more CECs per year.
- Averaging less than 8 CECs per year.

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Dale Sanitary District No 1 Wwtf

Last Updated: Reporting For:
5/17/2018 2017

Financial Management

<p>1. Provider of Financial Information</p> <p>Name: <input style="width: 150px;" type="text" value="Charles Zehner"/></p> <p>Telephone: <input style="width: 150px;" type="text" value="920-779-4084"/> (XXX) XXX-XXXX</p> <p>E-Mail Address (optional): <input style="width: 300px;" type="text" value="cdzehner@gmail.com"/></p>													
<p>2. Treatment Works Operating Revenues</p> <p>2.1 Are User Charges or other revenues sufficient to cover O&M expenses for your wastewater treatment plant AND/OR collection system ?</p> <p><input checked="" type="radio"/> Yes (0 points)</p> <p><input type="radio"/> No (40 points)</p> <p>If No, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>2.2 When was the User Charge System or other revenue source(s) last reviewed and/or revised?</p> <p>Year: <input style="width: 100px;" type="text" value="2015"/></p> <p><input checked="" type="radio"/> 0-2 years ago (0 points)</p> <p><input type="radio"/> 3 or more years ago (20 points)</p> <p><input type="radio"/> N/A (private facility)</p> <p>2.3 Did you have a special account (e.g., CWWP required segregated Replacement Fund, etc.) or financial resources available for repairing or replacing equipment for your wastewater treatment plant and/or collection system?</p> <p><input checked="" type="radio"/> Yes (0 points)</p> <p><input type="radio"/> No (40 points)</p>	0												
<p>REPLACEMENT FUNDS [PUBLIC MUNICIPAL FACILITIES SHALL COMPLETE QUESTION 3]</p>													
<p>3. Equipment Replacement Funds</p> <p>3.1 When was the Equipment Replacement Fund last reviewed and/or revised?</p> <p>Year: <input style="width: 150px;" type="text" value="2015"/></p> <p><input checked="" type="radio"/> 1-2 years ago (0 points)</p> <p><input type="radio"/> 3 or more years ago (20 points)</p> <p><input type="radio"/> N/A</p> <p>If N/A, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>													
<p>3.2 Equipment Replacement Fund Activity</p> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 60%;">3.2.1 Ending Balance Reported on Last Year's CMAR</td> <td style="width: 10%; text-align: right;">\$</td> <td style="width: 30%; text-align: right;"><input style="width: 100%;" type="text" value="11,833.02"/></td> </tr> <tr> <td>3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)</td> <td style="text-align: right;">\$</td> <td style="text-align: right;"><input style="width: 100%;" type="text" value="0.00"/></td> </tr> <tr> <td>3.2.3 Adjusted January 1st Beginning Balance</td> <td style="text-align: right;">\$</td> <td style="text-align: right;"><input style="width: 100%;" type="text" value="11,833.02"/></td> </tr> <tr> <td>3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)</td> <td style="text-align: right;">\$</td> <td style="text-align: right;"><input style="width: 100%;" type="text" value="0.00"/></td> </tr> </table>	3.2.1 Ending Balance Reported on Last Year's CMAR	\$	<input style="width: 100%;" type="text" value="11,833.02"/>	3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)	\$	<input style="width: 100%;" type="text" value="0.00"/>	3.2.3 Adjusted January 1st Beginning Balance	\$	<input style="width: 100%;" type="text" value="11,833.02"/>	3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)	\$	<input style="width: 100%;" type="text" value="0.00"/>	
3.2.1 Ending Balance Reported on Last Year's CMAR	\$	<input style="width: 100%;" type="text" value="11,833.02"/>											
3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)	\$	<input style="width: 100%;" type="text" value="0.00"/>											
3.2.3 Adjusted January 1st Beginning Balance	\$	<input style="width: 100%;" type="text" value="11,833.02"/>											
3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)	\$	<input style="width: 100%;" type="text" value="0.00"/>											

Compliance Maintenance Annual Report

Dale Sanitary District No 1 Wwtf

Last Updated: Reporting For:
5/17/2018 2017

<p>3.2.5 Subtractions from Fund (e.g., equipment replacement, major repairs - use description box 3.2.6.1 below*) - \$ 0.00</p> <p>3.2.6 Ending Balance as of December 31st for CMAR Reporting Year \$ 11,833.02</p> <p>All Sources: This ending balance should include all Equipment Replacement Funds whether held in a bank account(s), certificate(s) of deposit, etc.</p> <p>3.2.6.1 Indicate adjustments, equipment purchases, and/or major repairs from 3.2.5 above. <input style="width: 100%; height: 20px;" type="text"/></p> <p>3.3 What amount should be in your Replacement Fund? \$ 1.00</p> <p>Please note: If you had a CWFPP loan, this amount was originally based on the Financial Assistance Agreement (FAA) and should be regularly updated as needed. Further calculation instructions and an example can be found by clicking the SectionInstructions link under Info header in the left-side menu.</p> <p>3.3.1 Is the December 31 Ending Balance in your Replacement Fund above, (#3.2.6) equal to, or greater than the amount that should be in it (#3.3)?</p> <p><input checked="" type="radio"/> Yes <input type="radio"/> No</p> <p>If No, please explain. <input style="width: 100%; height: 20px;" type="text"/></p>	0								
<p>4. Future Planning</p> <p>4.1 During the next ten years, will you be involved in formal planning for upgrading, rehabilitating, or new construction of your treatment facility or collection system?</p> <p><input checked="" type="radio"/> Yes - If Yes, please provide major project information, if not already listed below. <input type="radio"/> No</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 10%;">Project #</th> <th style="width: 60%;">Project Description</th> <th style="width: 15%;">Estimated Cost</th> <th style="width: 15%;">Approximate Construction Year</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">1</td> <td>Wastewater Treatment Facility Planning</td> <td style="text-align: center;">20000</td> <td></td> </tr> </tbody> </table>		Project #	Project Description	Estimated Cost	Approximate Construction Year	1	Wastewater Treatment Facility Planning	20000	
Project #	Project Description	Estimated Cost	Approximate Construction Year						
1	Wastewater Treatment Facility Planning	20000							
<p>5. Financial Management General Comments <input style="width: 100%; height: 20px;" type="text"/></p>									
<p>ENERGY EFFICIENCY AND USE</p>									
<p>6. Collection System</p> <p>6.1 Energy Usage</p> <p>6.1.1 Enter the monthly energy usage from the different energy sources:</p> <p>COLLECTION SYSTEM PUMPAGE: Total Power Consumed</p> <p>Number of Municipally Owned Pump/Lift Stations: <input style="width: 50px; text-align: center;" type="text" value="1"/></p>									

Compliance Maintenance Annual Report

Dale Sanitary District No 1 Wwtf

Last Updated: Reporting For:
5/17/2018 2017

	Electricity Consumed (kWh)	Natural Gas Consumed (therms)
January	429	3
February	318	1
March	321	2
April	334	4
May	298	2
June	280	15
July	436	38
August	274	2
September	294	2
October	333	2
November	311	2
December	373	2
Total	4,001	75
Average	333	6

6.1.2 Comments:

rebuildt 1 flyt pump

6.2 Energy Related Processes and Equipment

6.2.1 Indicate equipment and practices utilized at your pump/lift stations (Check all that apply):

- Comminution or Screening
- Extended Shaft Pumps
- Flow Metering and Recording
- Pneumatic Pumping
- SCADA System
- Self-Priming Pumps
- Submersible Pumps
- Variable Speed Drives
- Other:

6.2.2 Comments:

the two flygt pumps running time meters are read daily. the channel grinder at the plant was rebuildt in June 2017 .

6.3 Has an Energy Study been performed for your pump/lift stations?

No

Yes

Year:

By Whom:

Describe and Comment:

Compliance Maintenance Annual Report

Dale Sanitary District No 1 Wwtf

Last Updated: Reporting For:
5/17/2018 2017

6.4 Future Energy Related Equipment

6.4.1 What energy efficient equipment or practices do you have planned for the future for your pump/lift stations?

none

7. Treatment Facility

7.1 Energy Usage

7.1.1 Enter the monthly energy usage from the different energy sources:

TREATMENT PLANT: Total Power Consumed/Month

	Electricity Consumed (kWh)	Total Influent Flow (MG)	Electricity Consumed/Flow (kWh/MG)	Total Influent BOD (1000 lbs)	Electricity Consumed/Total Influent BOD (kWh/1000lbs)	Natural Gas Consumed (therms)
January	9,520	0.94	10,128	1.33	7,158	
February	10,080	0.77	13,091	1.43	7,049	
March	9,520	1.06	8,981	4.03	2,362	
April	8,840	1.22	7,246	1.38	6,406	
May	8,080	1.04	7,769	1.36	5,941	
June	7,240	0.78	9,282	1.68	4,310	
July	7,560	0.71	10,648	1.36	5,559	
August	8,360	0.62	13,484	1.33	6,286	
September	7,760	0.62	12,516	1.47	5,279	
October	8,040	0.73	11,014	2.08	3,865	
November	7,280	0.61	11,934	1.47	4,952	
December	8,960	0.64	14,000	2.26	3,965	
Total	101,240	9.74		21.18		0
Average	8,437	0.81	10,841	1.77	5,261	0

7.1.2 Comments:

7.2 Energy Related Processes and Equipment

7.2.1 Indicate equipment and practices utilized at your treatment facility (Check all that apply):

- Aerobic Digestion
- Anaerobic Digestion
- Biological Phosphorus Removal
- Coarse Bubble Diffusers
- Dissolved O2 Monitoring and Aeration Control
- Effluent Pumping
- Fine Bubble Diffusers
- Influent Pumping
- Mechanical Sludge Processing
- Nitrification
- SCADA System
- UV Disinfection
- Variable Speed Drives
- Other:

Compliance Maintenance Annual Report

Dale Sanitary District No 1 Wwtf

Last Updated: Reporting For:
5/17/2018 2017

7.2.2 Comments:

changed fine bubble membranes in October of 2017.

7.3 Future Energy Related Equipment

7.3.1 What energy efficient equipment or practices do you have planned for the future for your treatment facility?

none at this time.

8. Biogas Generation

8.1 Do you generate/produce biogas at your facility?

No

Yes

If Yes, how is the biogas used (Check all that apply):

Flared Off

Building Heat

Process Heat

Generate Electricity

Other:

9. Energy Efficiency Study

9.1 Has an Energy Study been performed for your treatment facility?

No

Yes

Entire facility

Year:

By Whom:

Describe and Comment:

Part of the facility

Year:

By Whom:

Describe and Comment:

Compliance Maintenance Annual Report

Dale Sanitary District No 1 Wwtf

Last Updated: Reporting For:
5/17/2018 2017

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Dale Sanitary District No 1 Wwtf

Last Updated: Reporting For:
5/17/2018 2017

Sanitary Sewer Collection Systems

1. Capacity, Management, Operation, and Maintenance (CMOM) Program

1.1 Do you have a CMOM program that is being implemented?

- Yes
- No

If No, explain:

1.2 Do you have a CMOM program that contains all the applicable components and items according to Wisc. Adm Code NR 210.23 (4)?

- Yes
- No (30 points)
- N/A

If No or N/A, explain:

1.3 Does your CMOM program contain the following components and items? (check the components and items that apply)

- Goals [NR 210.23 (4)(a)]

Describe the major goals you had for your collection system last year:

clean and televise 20% of sanitary sewer , perform manhole inspections on 20% of the system every year , contract with an outside firm for annual maintenance on our main lift station .

Did you accomplish them?

- Yes
- No

If No, explain:

- Organization [NR 210.23 (4) (b)]

Does this chapter of your CMOM include:

- Organizational structure and positions (eg. organizational chart and position descriptions)
- Internal and external lines of communication responsibilities
- Person(s) responsible for reporting overflow events to the department and the public

- Legal Authority [NR 210.23 (4) (c)]

What is the legally binding document that regulates the use of your sewer system?

main rules of the Dale Sanitary District Sewer Ordinance

If you have a Sewer Use Ordinance or other similar document, when was it last reviewed and revised? (MM/DD/YYYY) 2013-06-15

Does your sewer use ordinance or other legally binding document address the following:

- Private property inflow and infiltration
- New sewer and building sewer design, construction, installation, testing and inspection
- Rehabilitated sewer and lift station installation, testing and inspection
- Sewage flows satellite system and large private users are monitored and controlled, as necessary
- Fat, oil and grease control
- Enforcement procedures for sewer use non-compliance
- Operation and Maintenance [NR 210.23 (4) (d)]

Does your operation and maintenance program and equipment include the following:

- Equipment and replacement part inventories
- Up-to-date sewer system map

Compliance Maintenance Annual Report

Dale Sanitary District No 1 Wwtf

Last Updated: Reporting For:
5/17/2018 2017

A management system (computer database and/or file system) for collection system information for O&M activities, investigation and rehabilitation
 A description of routine operation and maintenance activities (see question 2 below)
 Capacity assessment program
 Basement back assessment and correction
 Regular O&M training
 Design and Performance Provisions [NR 210.23 (4) (e)]
 What standards and procedures are established for the design, construction, and inspection of the sewer collection system, including building sewers and interceptor sewers on private property?
 State Plumbing Code, DNR NR 110 Standards and/or local Municipal Code Requirements
 Construction, Inspection, and Testing
 Others:

Overflow Emergency Response Plan [NR 210.23 (4) (f)]
 Does your emergency response capability include:
 Responsible personnel communication procedures
 Response order, timing and clean-up
 Public notification protocols
 Training
 Emergency operation protocols and implementation procedures
 Annual Self-Auditing of your CMOM Program [NR 210.23 (5)]
 Special Studies Last Year (check only those that apply):
 Infiltration/Inflow (I/I) Analysis
 Sewer System Evaluation Survey (SSES)
 Sewer Evaluation and Capacity Management Plan (SECAP)
 Lift Station Evaluation Report
 Others:

0

2. Operation and Maintenance

2.1 Did your sanitary sewer collection system maintenance program include the following maintenance activities? Complete all that apply and indicate the amount maintained.

Cleaning	<input type="text" value="20"/>	% of system/year
Root removal	<input type="text" value="20"/>	% of system/year
Flow monitoring	<input type="text" value="0"/>	% of system/year
Smoke testing	<input type="text" value="0"/>	% of system/year
Sewer line televising	<input type="text" value="20"/>	% of system/year
Manhole inspections	<input type="text" value="20"/>	% of system/year
Lift station O&M	<input type="text" value="1"/>	# per L.S./year
Manhole rehabilitation	<input type="text" value="4"/>	% of manholes rehabbed
Mainline rehabilitation	<input type="text" value="0"/>	% of sewer lines rehabbed
Private sewer inspections	<input type="text" value="0"/>	% of system/year

Compliance Maintenance Annual Report

Dale Sanitary District No 1 Wwtf

Last Updated: Reporting For:
5/17/2018 2017

Private sewer I/I removal	<input style="width: 90%;" type="text" value="0"/>	% of private services
River or water crossings	<input style="width: 90%;" type="text" value="0"/>	% of pipe crossings evaluated or maintained
Please include additional comments about your sanitary sewer collection system below:		
<input style="width: 100%;" type="text"/>		

3. Performance Indicators

3.1 Provide the following collection system and flow information for the past year.

32.51	Total actual amount of precipitation last year in inches
32.80	Annual average precipitation (for your location)
2.91	Miles of sanitary sewer
1	Number of lift stations
0	Number of lift station failures
0	Number of sewer pipe failures
1	Number of basement backup occurrences
0	Number of complaints
0.0266	Average daily flow in MGD (if available)
0.0404	Peak monthly flow in MGD (if available)
	Peak hourly flow in MGD (if available)

3.2 Performance ratios for the past year:

0.00	Lift station failures (failures/year)
0.00	Sewer pipe failures (pipe failures/sewer mile/yr)
0.00	Sanitary sewer overflows (number/sewer mile/yr)
0.34	Basement backups (number/sewer mile)
0.00	Complaints (number/sewer mile)
1.5	Peaking factor ratio (Peak Monthly: Annual Daily Avg)
0.0	Peaking factor ratio (Peak Hourly: Annual Daily Avg)

4. Overflows

LIST OF SANITARY SEWER (SSO) AND TREATMENT FACILITY (TFO) OFERFLOWS REPORTED **				
	Date	Location	Cause	Estimated Volume (MG)
None reported				

** If there were any SSOs or TFOs that are not listed above, please contact the DNR and stop work on this section until corrected.

5. Infiltration / Inflow (I/I)

5.1 Was infiltration/inflow (I/I) significant in your community last year?

Yes

No

If Yes, please describe:

5.2 Has infiltration/inflow and resultant high flows affected performance or created problems in your collection system, lift stations, or treatment plant at any time in the past year?

Yes

Compliance Maintenance Annual Report

Dale Sanitary District No 1 Wwtf

Last Updated: Reporting For:

5/17/2018

2017

<p>● No</p> <p>If Yes, please describe:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>
<p>5.3 Explain any infiltration/inflow (I/I) changes this year from previous years:</p> <div style="border: 1px solid black; padding: 2px;">was lower than last year</div>
<p>5.4 What is being done to address infiltration/inflow in your collection system?</p> <div style="border: 1px solid black; padding: 2px;">on-going sanitary sewer cleaning , televising and manhole inspection program , with repairs made as needed .</div>

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Dale Sanitary District No 1 Wwtf

Last Updated: Reporting For:
5/17/2018 2017

Grading Summary

WPDES No: 0030830

SECTIONS	LETTER GRADE	GRADE POINTS	WEIGHTING FACTORS	SECTION POINTS
Influent	A	4	3	12
BOD/CBOD	A	4	10	40
TSS	A	4	5	20
Ponds	A	4	7	28
Biosolids	A	4	5	20
Staffing/PM	A	4	1	4
OpCert	A	4	1	4
Financial	A	4	1	4
Collection	A	4	3	12
TOTALS			36	144
GRADE POINT AVERAGE (GPA) = 4.00				

Notes:

- A = Voluntary Range (Response Optional)
- B = Voluntary Range (Response Optional)
- C = Recommendation Range (Response Required)
- D = Action Range (Response Required)
- F = Action Range (Response Required)

Compliance Maintenance Annual Report

Dale Sanitary District No 1 Wwtf

Last Updated: Reporting For:
5/17/2018 2017

Resolution or Owner's Statement

Name of Governing
Body or Owner:

Dale Sanitary District

Date of Resolution or
Action Taken:

2018-05-15

Resolution Number:

2018-01

Date of Submittal:

ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO SPECIFIC CMAR
SECTIONS (Optional for grade A or B. Required for grade C, D, or F):

Influent Flow and Loadings: Grade = A

Effluent Quality: BOD: Grade = A

Effluent Quality: TSS: Grade = A

Ponds: Grade = A

Biosolids Quality and Management: Grade = A

Staffing: Grade = A

Operator Certification: Grade = A

Financial Management: Grade = A

Collection Systems: Grade = A

(Regardless of grade, response required for Collection Systems if SSOs were reported)

ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO THE OVERALL
GRADE POINT AVERAGE AND ANY GENERAL COMMENTS

(Optional for G.P.A. greater than or equal to 3.00, required for G.P.A. less than 3.00)

G.P.A. = 4.00